

TWENTY TWENTY-THREE
DRINKING WATER QUALITY REPORT

City of Cornwall, Ontario

2023



In accordance with *Section 11 and Schedule 22 of Ontario Drinking Water Regulation 170/03* under the *Safe Drinking Water Act*, the Environmental Services Division of the City of Cornwall is pleased to present the *2023 Drinking Water Quality Report*.

We're happy to report that we've continuously delivered **CLEAN and SAFE** drinking water to the residents and businesses of Cornwall, and that there were no Corrective Actions for our system from January 1st to December 31st, 2023.

The quality of our drinking water is **continuously monitored** and **tested** by advanced on-line instrumentation and a modern and secure *Supervisory Control and Data Acquisition (SCADA)* system. Additionally, the system is operated and maintained by **highly qualified** City staff members who have successfully completed rigorous training and testing to become certified *Drinking Water Treatment & Distribution System Operators*.

Department of Infrastructure & Municipal Works

Environmental Services Division
861 Second Street West
Cornwall, Ontario, Canada
Phone: 613-932-2235
Fax: 613-932-4506

MARCH 2024

Inside

Reporting Period	I
System	1
Source Quality	2
Source Protection	3
Water Conservation	4
Raw Water	5
Filtration	6
Disinfection	7
Advanced Treatment	8
High Lift Pumping	9
Distribution System	10
Elevated Storage Tank	11
Boundary Road Reservoir	12
Drinking Water System Diagram	13
Quality	14
Sampling	15
Infrastructure	16
Investments & Improvements	17
Safe Drinking Water Act	18
Sustainability	19
Treated Summary	20
People	21
Contact Us	22
Summary Report	App

2023

DID YOU KNOW?

Though it may look clean, **untreated** water could contain *microscopic contaminants* that might be **harmful** or possibly even **deadly** if consumed.

Micro-organisms like *viruses, bacteria and parasites* can be impossible to see with the naked eye. That's why **we treat every single drop** of water in our system and continuously **sample** and **test** it to make sure there's nothing harmful hiding in your taps.

Original document written by: Daniel G. DROUIN, A.Sc.T.
Supervisor of WATER DISTRIBUTION
and WASTEWATER COLLECTION
written and prepared by: Beau CHEESEMAN
SCADA and INSTRUMENTATION Technologist at WATER
PURIFICATION PLANT

photos by: Vitaliy ZHYDKYKH

System

The Corporation of the City of Cornwall owns and operates the **Cornwall Drinking Water System**, a Large Municipal Residential system.

It's made up of the *Raw Water Intake & Zebra Mussel Control Facilities* located at the base of the R.H. Saunders Power Generating Station Dam; the *Water Purification Plant*, a **class III water treatment facility**, located at 861 Second St. West; the *Boundary Road Reservoir*, the *Elevated Storage Tank* located on Tollgate Rd. and we operate the *City's Distribution System* which is also classified **class III**.

We take water from the *St. Lawrence River* and treat it according to **standard surface water treatment** methods before it's distributed to your homes and businesses.

The **Water Purification Plant** uses chemically assisted *coagulation* and *flocculation* to remove particles suspended in the raw water. The water is then *filtered* and treated with *UV light* and *chlorine* for **disinfection**.



“The Water Purification Plants’ determined team effort throughout another challenging year ensured drinking water quality once again not only met but exceeded all legislative requirements for City residents and business in 2023.”

-Owen O’KEEFE, C. Tech
SUPERVISOR of the WATER PURIFICATION PLANT

- LICENSE #: 176-101, issue 3
- PERMIT #: 176-201, issue 6
- SYSTEM #: 220001049

*“Our entire water distribution network is a **critical piece of infrastructure** that we are proud to maintain 24 hours a day, 7 days a week. **Providing clean & safe drinking water is our priority.**”*

-Shawn O’BRIEN
MANAGER of MUNICIPAL WORKS

Source Quality

RAW WATER

	MIN.	AVG.	MAX.
Turbidity	0.18	0.55	19.99
pH	7.55	7.86	8.30
colour	2	5	9

EXAMPLES OF TURBIDITY:



Note how the water becomes "cloudier" as the NTU increases.

Lake St. Lawrence is a stable and reliable source of water that is part of the St. Lawrence River system. The lake was formed on July 1st, 1958 through the intentional flooding of the area known as "The Lost Villages".

On December 1, 2023, the Ontario MECP issued us our most recent *Permit to Take Water* (PTTW) from Lake St. Lawrence. This permit stipulates that we are allowed to take a **maximum of 100,000,000 litres of water per day**. We removed an average of 32,643,000 litres per day and reached a

maximum of 48,703,000 litres per day.

The *turbidity*, or relative clarity of a liquid, in Cornwall's raw water averaged 0.55 Nephelometric Turbidity Units (NTU) and reached a maximum of 19.99 NTU on November 2nd.


A total of **52** regularly scheduled raw water samples were taken and submitted to an MECP accredited laboratory for *E. coli* and *Total Coliform* testing and analysis, as directed by the *Ontario Drinking Water Regulation 170/03*.

Testing results indicated that an average of 8 *Colony-Forming Units* (CFU) of *E. coli* and 24 CFU of *total coliform* were found per every 100 ml of raw untreated water taken from Lake St. Lawrence in 2023.

The raw water enters the purification system through the Raw Water Intake and Bar Screen that is built into the west side of the *R.H. Saunders Generating Station Dam*, **15 metres below the surface** of Lake St. Lawrence.

Raw Water Volume

Our permit to take water stipulates that we can remove up to **100,000,000 litres** of water per day.



Average Daily Volume

In 2023, the city withdrew an average of **32,643,000 litres of water per day**.

Maximum Daily Volume

On June 1st we withdrew **48,703,000 litres** of water. This was the highest daily volume of water we removed in 2023.

0.55ntu
average turbidity before treatment

As mentioned, our **source water** comes from the *St. Lawrence River System*, and to keep it as **clean as possible** a plan has been put into place through the *Ontario Clean Water Act*. An *Assessment Report* and *Source Water Protection Plan* was developed by the *Raisin - South Nation Source Protection Committee* and implemented in 2015 to keep contaminants away from our raw water intake.

This *Assessment Report* identifies our Source Protection Area and the various activities that could potentially pose a **threat** to either the **quality** or **quantity** of our raw water supply. Our Source Protection Area includes two *Intake Protection Zones* (IPZ #1, IPZ #2 below) that are classified by their **distance** from our raw water intake, and the **time** it would take for contaminated water to travel to it.


We've also developed a *Source Water Protection Implementation Guide* back in 2015, to help us ensure we have the tools we need to meet or exceed all our obligations under the *Ontario Clean Water Act*.

Protecting our source water is the most important thing we can do to keep our drinking water clean and safe!



Raw Water Flowrate

Our permit to take water states that we can remove water from the St. Lawrence River up to a maximum flow rate of **125,000 litres per minute**.



Average Flow Rate

In 2023, we withdrew water at an average rate of **22,689 litres per minute**.

Peak Flow Rate


On March 23rd we withdrew water at a rate of **104,160 litres per minute** for approximately **15 minutes**. This was the highest raw water flow rate we experienced in 2023.

Source Protection

Conservation

Water is essential to our daily lives, and there is a potential for water conservation both **inside** and **outside** of your home whenever it's used. Sensible water use can **reduce the amount of stress** that is placed on our **major resources** such as the water purification and wastewater treatment plants, and the distribution system that delivers water to you.

Here are some helpful tips for water conservation:



If we created a moon with **all** of Earth's water, it would have a diameter of **1,385 km**.

If we did the same with **all of Earth's FRESH water**, it would have a diameter of **272 km**.

Now, if the moon was only made with **all of Earth's ACCESSIBLE FRESH water**, it would only have a diameter of **56 km**.

Fresh Water makes up a very small fraction of all water on the planet. While nearly **70%** of the Earth is covered by water, only **2.5%** of it is fresh. The rest is saline and ocean based. Even then, **less than 1% of our freshwater is easily accessible**, with much of it trapped in glaciers and snowfields. (SOURCE: National Geographic Society)

INDOOR WATER CONSERVATION TIPS

- Install aerator attachments on sink faucets.
- Replace or adapt older, less water efficient fixtures or appliances.
- Take short showers. Replace your showerhead with a water saving device such as an ultra-low-flow version.
- When bathing, be careful not to overfill the tub. A ¼ full tub is usually sufficient.
- Don't let water run while shaving, washing your face or brushing your teeth.
- Avoid flushing the toilet unnecessarily. Dispose of tissues and other similar waste in the trash rather than the toilet.
- When replacing a toilet, consider a low-flush toilet that uses a smaller water tank. Or you can install a water saving device in your present toilet to reduce the amount of water used during a flushing cycle.
- Operate automatic dishwashers and washing machines only when they are fully loaded.
- If something requires cleaning fill the sink instead of running a steady stream of water.
- When boiling vegetables use just enough water to cover them or consider steaming, which uses less water and conserves the natural nutrients.
- Do not use running water to thaw meat or other frozen foods. Instead consider defrosting food overnight in the refrigerator or using the defrost setting on your microwave.

OUTDOOR WATER CONSERVATION TIPS

- Use a broom to clean a driveway or a sidewalk rather than spraying it down with water.
- Watering outdoor greenery in the spring isn't always a good practice. The less it is watered early in the growing season, the deeper the roots will grow. This creates a greater natural reservoir.
- For lawn and garden watering use an appropriate sprinkler with an automatic shut-off nozzle that best suits your needs. Lawns should be watered no more than once every 3 to 5 days. Remember, evaporation rates are lower in the morning or early evening. At times when there are water shortages, lawns should not be watered at all.
- Ask your local gardener about drought resistant plants and ground coverings that will save upkeep time and water.
- Install moisture-holding mulch around trees and shrubs and keep weeds under control. Weeds can prevent much needed water from reaching other plants.
- Rainwater can be collected in large containers and used to water outdoor plants.
- When washing your car use a bucket and sponge, then quickly rinse with a trigger nozzle equipped hose.
- By not overfilling your swimming pool you can prevent water loss due to splashing. Swimming pool covers can also be used to prevent evaporation.



The raw water enters the purification system through a coated steel **Bar Screen** equipped with 10 cm spacing designed to prevent logs or other large objects from entering the intake pipe and clogging it. The special coating helps to prevent the formation of any *frazil ice* that could potentially clog or jam the bar screen.

Inspections by specially trained and certified SCUBA divers are completed on the intake system annually. The system was last inspected on **May 25th, 2023**, and both the Bar Screen and Raw Water Intake were again found to be in **excellent operating condition**.

Once through the Bar Screen the raw water is **pre-chlorinated** by the Zebra Mussel Control System then passes through a normally open gate valve.

The pre-chlorination of the raw water prevents the formation of **Zebra Mussels** that can grow inside of pipes and equipment which can cause severe clogging or jamming problems with the intake system, bar screen and gate valve.

The Zebra Mussel Control System is enclosed in a small facility located near the east side of the *R.H. Saunders Generating Station Dam*.

The Zebra Mussel Control Facility consists of a raw water recirculation pumping system, a raw water supply line, and gas chlorination equipment which include: chlorine gas cylinders, a weight scale, a chlorine gas feeder, monitoring instrumentation, and an automated chlorine injection control system.

The **chlorine gas** is mixed with the raw water to create a **hypochlorous acid** solution which is effective in reducing the growth of zebra mussels.

After being pre-chlorinated, the raw water is fed by hydraulic pressure through nearly **3.7 kilometres** of reinforced concrete pipe; then finally arrives at the Cornwall Water Purification Plant (WPP) to begin the treatment process.

Just before entering the plant the concrete pipe divides into two separate flow control lines which are individually controlled by motorized valves located in the WPP Flow Control Chamber.

These motorized valves modulate their position to adjust the flow of raw water streaming into the WPP. The valve positions are controlled by the level signal provided by the WPP Settling Tank ultrasonic level sensors. This control is done to maintain a constant water level in the settling tanks.

Also installed with the valves are magnetic flow meters and indicating transmitters which are used to continuously monitor and record the raw water flows.

One motorized valve and one flow meter are installed on a **600mm diameter flow control line** which is generally used during normal operating conditions.

The other motorized valve and flow meter are installed on a **900mm diameter line** which is used in situations where the City's water demands are significantly higher than usual or during the shut-down and maintenance of the 600mm flow control line.

Once the flow has been **measured and recorded** a chemical coagulant solution is injected against the flowing raw water to "flash mix" the coagulant solution with the water and begin the coagulation, flocculation and settling processes.

The water then flows through a new **Motorized Traveling Screen** where weeds, sticks, plastic bags, and other forms of debris which were able to pass through the Raw Water Intake's Bar Screen are removed from the water.

Raw Water

1.03mg/l

average zebra mussel control chlorine dose

0.29mg/l

average pre-treatment free chlorine residual

Filtration

Once past the Motorized Traveling Screen the flowing raw water and coagulant mixture enters the Pre-mix Chamber then divides into two separate, yet identical hydraulic flocculation Mixing Chamber systems (North and South) which operate in parallel.

Each Mixing Chamber system consists of three compartments. The **raw water and coagulant mixture** enter a center compartment where additional mixing is achieved. The water is then directed to the two outer compartments for final gentle mixing and to complete the **flocculation process**.

The water then flows from the flocculation compartments to one of two corresponding **Settling Tanks** which also operate in parallel (North and South). The Settling Tanks are equipped with baffles to ensure the proper **settling** of all **flocculation particles** before filtration.

The individual filters are **cleaned after every 24 hours of operation** by means of air scouring and backwashing with treated water.

In 2023, the Cornwall Water Purification Plan used an **aluminum based coagulant solution** to assist in the flocculation process at an average dosage of **12.41 mg/l**.

The effectiveness of the coagulant solution can vary (sometimes significantly) depending on the **temperature** of the water in which it is injected, particularly in low turbidity waters like those of Lake St. Lawrence. Cornwall's raw water temperature varied between **0.6° and 23.3° Celsius** in 2023.

Each Settling Tank is automatically cleaned every two days by an automated **sludge collection & removal system**. This system is used to remove the flocculation sludge that accumulates at the bottom of the tanks.

During these cleanings, the wastewater and accumulated sludge that's created by the settling process is directed to the sanitary sewer system.

After passing through the Settling Tanks the two separate water streams (North and South) recombine into a single **Settled Water Conduit** which directs the water to the Filter Bed System.

The **Filter Bed System** is comprised of four (4) conventional Filters Beds that have a surface area of **82m²** each, and which operate completely independently from one another.

The settled water enters the Filter Beds through horizontal troughs that run across the filters.

The water then travels down into the filter and through **porous anthracite** to trap and remove any remaining particulate matter that may still be suspended in the water. In 2023, coagulation, settling and filtration reduced the average turbidity in the water from 0.55NTU to 0.04 NTU.

All four of the Filter Beds have been upgraded in recent years and are equipped with anthracite media, improved lateral under-drain systems, and **air-scouring capabilities** which significantly increases the effectiveness of the **backwash cleaning process**.

FILTER EFFECTIVENESS

19.99 ntu

maximum raw water turbidity before filtration

0.04 ntu

average turbidity after filtration

DID YOU KNOW?

Ultraviolet light at wavelengths between **200 & 300 nm** (nanometers) and delivered in doses over **40mJ/cm²** (millijoules per square centimeter) are proven to be **extremely effective** at inactivating dangerous waterborne pathogens including viruses, bacteria, and parasites without creating any known harmful by-products. UV light is particularly effective at disinfecting micro-organisms that are resistant to chlorine.

135

mJ/cm²
average UV disinfection dose

Disinfection

Once the water has passed through one of the filters it's discharged into a corresponding **Filter Header** (#1, #2, #3, or #4) located in the Water Purification Plant's Pipe Gallery.

The Filter Headers direct the water to either the Clearwell, the Reservoir, or to waste (the sewer system), and each header is equipped with multiple **sensing devices** designed to **monitor** the **performance** of the filter and the quality & quantity of water (i.e. turbidimeters, differential pressure transmitters, magnetic flow meters, and UV transmittance sensors).

The Filter Headers are also where the water is disinfected with **Ultraviolet (UV) radiation** at an average dose of **135mJ/cm²** in 2023.

In addition to U.V. light, the Water Purification Plant also uses **chlorine** in the form of Sodium Hypochlorite (NaOCl) for **primary chlorination** and to provide **secondary disinfection**.

Primary chlorination and U.V. disinfection ensure the destruction or **inactivation of harmful pathogens** which are too small to be removed by coagulation, settling and filtration.

Secondary chlorine disinfection provides a **residual** concentration of free chlorine in the City's Distribution System to **prevent bacterial re-growth** and to provide a measurable way to quickly **detect unexpected changes** in the Distribution System's water quality.

Once the water has traveled through the Filter Headers it is (under normal operating conditions) directed to the **Clearwell** where the water is injected with an average dose of approximately **1.22 mg** (milligrams) of chlorine per liter of filtered water.

The Clearwell is a 1.515 million litre **baffled** water storage chamber which allows the chlorine to blend with the filtered water for a time.

The chlorine contact time in conjunction with the water's pH, temperature, and free chlorine residual allow plant operators to accurately predict the effectiveness of the chlorine disinfection process.

The treated water then moves from the Clearwell to a baffled 3.030 million litre buried **Reservoir** where additional chlorine contact time is achieved before the water is allowed to be discharged into the Distribution System by the High Lift Pumping System.

Chlorine residual levels at the Water Purification Plant are **continuously monitored and recorded** by five (5) chlorine analyzers which constantly sample & test water from strategic locations within the plant's process stream.

The data collected by the analyzers is securely stored in the plant's *Supervisory Control and Data Acquisition* (SCADA) System and on backup data storage devices.

0.27

mg/L

On July 18th we recorded a **minimum** free chlorine residual of 0.27 milligrams per litre. This brief **dip** was recorded during the **re-calibration** of a component in the chlorine monitoring system.

Harmful Algal Blooms (HABs) occur when *blue-green algae*, grow rapidly in water forming large visible patches. These HABs may produce **biotoxins** like *microcystin* that can be harmful to humans, plants and animals.

Our *monitoring plan* for HABs includes **weekly sampling** and **testing** (June-October) of the raw and treated water for *microcystin*. Average and maximum (<0.1-0.1µg/l) microcystin levels were **well below** concentrations that are believed to cause adverse health effects (1.50 µg/l).


Advanced Treatment

During the late summer, *algae* in the St. Lawrence River begin to die off. Their *decomposition* releases harmless compounds that cause even treated drinking water to taste and smell **earthy** or **musty**.

To help control the problem in the past, we have injected a small dose of **Hydrogen Peroxide** (H₂O₂) into the filtered water and then ramp up the Water Purification Plant's **UV reactors** (which normally operate at only 30% of their capacity) to full power.

This **Advanced Oxidation** treatment process reduced the levels of *Taste and Odour* compounds in the filtered water to below their detectable limits.

The system is typically only activated when *Taste and Odour* events have been detected by sampling activities and/or reported by the public. No events were detected or reported since 2018 therefore the system remained offline.



This graph demonstrates the effectiveness of our **advanced oxidation process** (AOP) on *Geosmin* (a taste and odour causing compound). 57 samples were taken at our water purification plant between 2009 and 2023.


High Lift Pumping

Once the water's been treated and is ready to be consumed, it's lifted from a water conduit that's fed from the Reservoir and pumped into a common **Discharge Ring Main header** located in the basement of the Water Purification Plant. The conduit can also be fed from the Clearwell when required. This pumping is done by one or more of the Water Purification Plant's five (5) **High Lift Discharge pumps**.

From the ring main, the water is directed to the **East** and **South Discharge Lines** where the individual flows are **monitored and recorded** as the water is discharged into the **Distribution System**. Other discharge water quality parameters are continuously monitored and recorded such as:

- the discharge water pressure.
- the discharge turbidity.
- and the post (or secondary) free chlorine residuals.

In 2023 the Water Purification Plant discharged a total of **11.18 billion litres of water** at an average rate of **30,635,342 litres of treated water per day**. Average post chlorine residuals of **1.19 mg/l** were also maintained.



11.18 BILLION litres pumped in 2023

Distribution System

The City's Municipal Works Department has implemented a **Distribution System Flushing Program** which ensures that chlorine residual levels in the Distribution System are being adequately maintained. This is accomplished by allowing distribution water to be discharged from fire hydrants and blow-offs for a specific amount of time then testing the water for free chlorine residual levels.

The **flushing activities** are carried out by Municipal Works staff and automated flushing systems in regularly scheduled intervals at strategic locations throughout the city.

The communities of *St. Andrews* and *Rosedale Terrace* in the Township of South Stormont were **connected** to the city's Distribution System in **1991**.


St. Andrews' water is supplied by a connection in an **underground valve chamber** located at the intersection of Cornwall Centre Road and Highway 138 (FCC-02), and *Rosedale Terrace* is supplied by a connection located beneath the intersection of Mack Street and Cornwall Centre Road (FCC-01).

Holy Trinity Catholic School in the Township of South Glengarry is also **connected** to the Cornwall Distribution System.

CITY of CORNWALL, ONTARIO, CANADA
CLASS III WATER TREATMENT & DISTRIBUTION SYSTEM
ONTARIO DRINKING WATER SYSTEM # 220001049



LEGEND



- BRR: Boundary Road Reservoir
- EST: Elevated Storage Tank
- FCC: Flow Control Chamber
- RWI: Raw Water Intake
- WPP: Water Purification Plant
- ZMC: Zebra Mussel Control Facility



Elevated Storage Tank

22.7 meters
tank diameter

15.4 meters
tank height

26.3 meters
base height

41.7 meters
total height

4.5 MILLION
litres of storage

The drinking water pumped from the Water Purification Plant enters the Distribution System and flows to the **Elevated Storage Tank** located at 401 Tollgate Road, between McConnell Avenue and Pitt Street in Cornwall.

The Elevated Storage Tank is a composite tower comprised of a 15.4-metre-tall **steel bell** with the capacity to hold **4,545,000 litres** of treated water, secured to the top of a 26.3-metre-tall concrete base.

The city commissioned the Elevated Storage Tank in 1991 to act as an **emergency reservoir**, and to help **maintain and balance the pressure** in all areas of the City's Distribution System. Many safety features were upgraded and its exterior and portions of the interior were recoated in 2015.

The tank's **water level** is monitored and recorded by 2 separate Level Indicating Transmitters. The level varies during the day depending on the city's **demand**; however, a

minimum operating level is maintained, and additional High Lift Pumps are automatically activated at the Water Purification Plant if the level drops too low.

Pressure Indicating Transmitters monitor and record the Distribution System water **pressure** in the north end of the city.

Free chlorine residual levels are **constantly monitored** by a newly upgraded *Elevated Tank Chlorine Injection and Monitoring System* comprised of a combination of pH and chlorine analyzing probes, a transmitter, and an automated Sodium Hypochlorite injection system which maintains the free chlorine residuals at approximately **0.85 mg/l**.

To maintain uniform free chlorine residuals and prevent freezing in the winter months, the water in the Elevated Storage Tank is in **constant circulation** with the help of a re-circulation pumping and flow monitoring system.



Boundary Road Reservoir

Water from the Distribution System is also stored in the **Boundary Road Reservoir** located at 560 Boundary Road in Cornwall.

The reservoir was commissioned in 1973 to act as an additional **water storage facility** in the event of fire related emergencies and to **augment** the Distribution System's **water pressure** in the eastern portion of the city.

The reservoir has the capacity to store **9,100,000 litres** of water in two separate underground chambers.

It also serves as a water pressure **booster pumping station** equipped with three centrifugal Booster Pumps each capable of transferring approximately **110 litres** of water per second from the reservoir and into the Distribution System.

To maintain **free chlorine residuals**, the water in the reservoir is "**turned over**" daily.

Turning-over involves **two steps**:

First, is an automated process that occurs at nighttime, and which **deactivates the Booster Pumps** and **opens the Inlet Valve** to allow water from the Distribution System to fill the reservoir.

The **second step** occurs during the daytime when the **Inlet Valve** allowing water into the reservoir is **closed** and one or more **Booster Pumps are activated** to reduce the volume of water stored in the Boundary Road Reservoir.

The constant draining and re-filling of the reservoir ensures that the free chlorine residuals are sufficient to **prevent the growth of algae or bacteria**.

Free chlorine residual levels in the Boundary Road Reservoir are also **constantly monitored** by the newly upgraded *Boundary Road Chlorine Injection and Monitoring System*.

The system is comprised of one combination pH and chlorine analyzing transmitters which sample and monitor the free chlorine residuals of the Distribution System water as it enters the reservoir, a second combination of pH and chlorine analyzing transmitters which sample and monitor the water as it is pumped out of the reservoir, and an automated chlorine injection system which maintains the chlorine residuals of the water discharged from the reservoir at approximately **0.82 mg/l**.

In the event of a utility power failure, the Boundary Road Reservoir is equipped with a **300-kW diesel generator** set which provides emergency power. The generator set was installed in 2010.



1973
commissioned

9.1 MILLION
litres of storage


0.82 mg/l
avg.
free cl² residual

drinking water system

LICENSE # 176-101, issue 3
 PERMIT # 176-201, issue 6
 SYSTEM # 220001049

CITY OF CORNWALL DRINKING WATER QUALITY MANAGEMENT SYSTEM POLICY:

- Continually providing safe and clean drinking-water to City customers
- Legislative compliance with the Safe Drinking Water Act and related regulations
- Establishing, maintaining, and continually improving our Drinking Water Quality Management System
- Acting to resolve any issues relating to drinking-water quality.
- Reviewing and improving our drinking-water system infrastructure.



LEGEND

- B** - Air Scour Blower
- C** - Free Chlorine Monitor
- P** - Pump
- R** - Ultra Violet (UV) Reactor
- T** - Turbidity Monitor
- U** - UV Transmittance

Quality

To ensure Cornwall's water is **clean** and **safe**, distribution samples are regularly taken, and laboratory tested for various parameters.

The sampling and testing parameters which apply to Cornwall's Drinking Water System are outlined in **Schedules 10, 13, 15, 23, and 24** of O.Reg.170/03 under the Safe Drinking Water Act of 2002.

Schedule 10 requires that one (1) raw water sample and one (1) treated water sample be tested per week for **Escherichia coli** (E. coli) and **total coliforms**, and that a minimum of 55 samples per month be taken from at least 8 different locations in the Distribution System and be tested for the same parameters.


Water Purification Plant staff collected weekly samples from **15 different locations** throughout the city in 2023 and submitted them to an **accredited laboratory** for testing.

The testing results of **52 treated water samples**, and all **773 distribution water samples** collected in 2023 indicated that there was no trace of total coliforms or E. coli in the City's drinking water.

Schedule 10 also requires that the general bacteria population of one treated water sample and 25% of the weekly distribution samples be tested and expressed in **Heterotrophic Plate Count** (HPC).

In 2023, **52 treated water samples** and **260 Distribution System water samples** were submitted to an accredited laboratory for HPC testing.

All HPC testing results indicated that Cornwall's drinking water is of **excellent quality and is safe for consumption**.



Satellite view of the City of Cornwall with pins representing our various sampling locations.

Schedule 13 of O.Reg.170/03 requires that the City's drinking water be sampled and tested for **trihalomethane (THM), haloacetic acid (HAA), nitrate & nitrite** levels once every three months, and that sodium levels be sampled and tested annually.

Laboratory results for 2023 indicate that the concentration levels of all parameters listed under Schedules 13 were **well below their respective allowable concentration limits**.

Simply put, independent laboratory results confirm that the treated drinking water we produce **exceeds all quality standards, is clean, safe and tastes great!**


Sampling

WEEKLY BACTERIOLOGICAL SAMPLING & TESTING (Schedule 10)
Total Coliforms and E. coli (*Escherichia coli*)

Background Heterotrophic Plate Count


52 treated water samples – No Unsafe Samples
 260 distribution water samples – No Unsafe Samples

QUARTERLY DISTRIBUTION DISINFECTION BY-PRODUCT and CHEMICALS SAMPLING & TESTING (Schedule 13)



* No Provincial Standards exist for these parameters; therefore, they have been scaled to 100µg/L

BI-ANNUAL DISTRIBUTION LEAD SAMPLING & TESTING (Schedule 15.1)



**The City is entitled to operate a reduced lead sampling program as prescribed under schedule 15.1-5 of Ontario Regulation 170/03.

52 RAW WATER samples

RAW RESULTS

Total Coliforms Monthly Average: 23.67 cfu/100ml
 E. coli Monthly Average: 7.51 cfu/100ml

52 TREATED WATER samples

TREATED RESULTS

No Total Coliforms detected.
 No E. coli detected.

773 DISTRIBUTION samples 15 locations

DISTRIBUTION RESULTS

No Total Coliforms detected.
 No E. coli detected.

ANNUAL TREATED WATER CHEMICAL SAMPLING & TESTING (Schedule 13, 15.2, 23, 24)

Alachlor • Antimony • Arsenic • Atrazine + N-dealkylated metabolites • Azinphos-Methyl • Barium • Benzene • Benzo(a)pyrene • Boron • Bromoxynil • Cadmium • Carbaryl • Carbofuran • Carbon Tetrachloride • Chlorpyrifos • Chromium • Diazinon • Dicamba • 1,2-Dichlorobenzene • 1,4-Dichlorobenzene • 1,2-Dichloroethane • 1,1-Dichloroethylene • Dichloromethane • 2,4-Dichlorophenol • 2,4-Dichlorophenoxy Acetic Acid • Diclofop-methyl • Dimethoate • Diquat • Diuron • Fluoride • Glyphosate • Lead • Malathion • Mercury • 2-Methyl-4-chlorophenoxyacetic Acid • Metolachlor • Metribuzin • Monochlorobenzene • Paraquat • Pentachlorophenol • Phorate • Picloram • Polychlorinated Biphenyls • Prometryne • Selenium • Simazine • Sodium • Terbufos • Tetrachloroethylene • 2,3,4,6-Tetrachlorophenol • Triallate • Trichloroethylene • 2,4,6-Trichlorophenol • Trifluralin • Uranium • Vinyl chloride


The results of the annual samples indicated that the concentration levels of all of the parameters listed under Schedule 13, 23 & 24 of O.Reg.170/03 were below one-half of their respective allowable limits set out in the Provincial Standards.

Infrastructure

274 km pipe | **1,315 hydrants**
2,062 valves

Our water travels to your homes and businesses through a vast network of **underground water mains**. If we connected all the water main pipes end-to-end, it would be long enough to reach from **downtown Cornwall** all the way to **Albany, New York!**

WATER MAIN BREAKS



33 breaks in 2023

\$2.85 million Invested


We invested **\$2.85 million** on our distribution infrastructure this year. This consisted of many projects including the **replacements, repairs, and rehabilitations** of pipes throughout various portions of our water distribution network.

	STREET	FROM	TO	DIAMETER/LENGTH
\$975,175 RELINING	Sydney St	Eleventh St	Twelfth St	150mm/323.5m
	Queen St	Susan Av	Wallrich Av	150mm/470m
	Edythe Ave	Robertson Av	Wallrich Av	150mm/284.5m
\$1,877,098 REPLACEMENTS	Aberdeen Av	Marlborough St	Gloucester St	150/400mm/201/2m
	Fifth St E	Mcconnell Av	Marlborough St	150mm/132.6m
	Mcconnell Av	Fifth St E	Second St E	150mm/36m
	Lemay St – Part A	Aubin St	Sydney St	150/200mm/214/249m
	Fifth St E	York St	Pitt St	450/200/150mm/351/24/61m

“With precision and dedication, our team adeptly maintains over 274km of municipal water distribution piping, ensuring a seamless flow that mirrors their exceptional expertise and commitment to providing extraordinary service to the residents of Cornwall.”

- Dan DROUIN, A.Sc.T.
SUPERVISOR of WATER DISTRIBUTION and WASTEWATER COLLECTION

ANNUAL INVESTMENTS IN WATER DISTRIBUTION INFRASTRUCTURE



\$975 THOUSAND Investments and Improvements

PLC and CONTROL ROOM UPGRADES - \$950,000

The water plant is controlled and overseen by a **modern** and **secure** SCADA (Supervisory Control and Data Acquisition) system. The “brain” of this system is the **programmable logic controllers** or PLC’s. In 2023, the city completed a large upgrade project to modernize the existing equipment and ensure the plant is **running seamlessly** into the future with the **latest technology** and **engineering**. The upgrade was carried out with improved performance, durability and redundancy being the result.

In addition to the PLC hardware, the networking and communications system was upgraded to the latest in **fibre optics communications technology** and the terminals running our software were also replaced as they were at end of lifecycle.

This equipment controls everything in our system from the amount of water coming in and going out, to the overall **quality** and **clarity** of the final product. By upgrading to newer equipment, we are ensuring that we can **continuously monitor** and **control** our process with no downtime or gaps in the monitoring and treatment of our drinking water system for many years to come.



SECONDARY RAW WATER INTAKE REDUNDANCY TECHNICAL STUDIES - \$25,000

An *Environmental Assessment Process* was completed which evaluated **alternative solutions** and identified preferred locations for providing a **redundant secondary raw water intake**. This was followed by a *Stage 1 Archaeological Assessment* and an *Environmental Impact Assessment* completed in 2023. Further studies to be completed include a *Stage 2 Archaeological Assessment* and the completion of the *Conceptual Design*.

In 2024 allocation of funds will begin contributing to a reserve for the municipal component of the project with the intent of securing funding from the Provincial and Federal governments in the future for the **design** and **construction** of the project.

Ontario



Safe Drinking Water Act

We operate our *Water Treatment and Distribution Systems* under the laws and regulations created under the Province of Ontario's **Safe Drinking Water Act** of 2002.

The Act clearly recognizes that **people are entitled to expect safe drinking water** and provides for the **protection** of human health from drinking water health hazards through **controls, testing, and regulations**.

O.Reg. 128/04


Ensures that the **operators** working on Ontario's drinking water systems are **competent** and **licensed** to perform their duties. It establishes the ongoing training requirements, details the different types of licenses, reissuance and transferability, overall and operator in charge responsibilities, record keeping, and operations & maintenance manual requirements.

O.Reg. 169/03

Sets out the **drinking water quality standards** that we operate under, including the testing parameters of the various contaminants and their acceptable concentration limits.

O.Reg. 170/03

Applies to **municipal** and private water systems that provide water to residential areas year-round. It stipulates the **treatment methods**, operational checks, chemical and microbiological sampling and testing requirements, corrective actions, and the **reporting requirements**.



KEEPING ONTARIO'S DRINKING WATER SAFE!

O.Reg. 287/07

Applies to municipalities within **Source Water Protection Areas** and stipulates the requirements for coordination with Source Water Protection Committees, and the study and creation of specific area protection zones and plans.

O.Reg. 435/93

Sets out water treatment, water distribution, and wastewater collection and treatment system **Operating Standards**. It defines the various classifications of facilities, operator licensing fees and other general operating standards.

O.Reg. 453/07

Stipulates the need to prepare a **Financial Plan** that forecasts our financial requirements for at **least six years into the future**. The plan must be approved by a resolution of *City Council* and is required to be updated regularly before we can apply to renew our Operating License. Our most recent Financial Plan was completed in November of 2020.



Sustainability

As detailed in the *2021 Water Conservation and Servicing Master Plan*, the per capita water use in Cornwall is **significantly higher** than the provincial average. In response, the city launched a **Water Conservation Program** with the goal of providing all municipal water users with the tools, incentives, and **educational resources** to conserve water and **promote sustainable management** of the municipal water supply. **Notable achievements for 2023 include:**


- In June 2023, Council accepted the *Findings and Recommendations Report* prepared by Diameter Services Inc. which outlines the **project design** and **financial plan** for the installation of a **Universal Water Metering** and **Advanced Metering Infrastructure (AMI) Project**. This deliverable culminated in the **Phase 1- Design** and allowed the city to begin the procurement process.
- The City of Cornwall continues to offer a **Residential Toilet Rebate Program**. This Program promotes replacement of high-volume flush (13lpf or greater) toilets with **high efficiency** toilets (4.8lpf or less). An average household could **conserve over 33,000L** per year through the replacement of one low efficiency toilet.
- The City of Cornwall continues to offer **free Residential Water-Use Audits** to help residents identify where they use water in their homes and **highlight opportunities** to reduce household consumption. As part of these audits, residents will learn where to look for, and how to identify leaks, as well as some quick tips for how to modify their behaviours to use less water.
- On April 22, 2023, the city held a **Rain Barrel Sale** as part of their annual **Eco Day Celebration**. These affordable, **upcycled rain barrels** are constructed using recycled food grade canisters which would otherwise be landfilled. **Rainwater** is a great **alternative** to treated water for many outdoor purposes such as **lawn and garden irrigation** or car washing.
- On September 5, 2023, the city delivered an interactive station as part of the **Eastern Ontario Children's Water Festival**, hosted by the **St. Lawrence River Institute**. This station helped young minds understand the complex process that occurs that makes water **safe to drink** before it reaches the tap at their home or school.

For more information and water conservation tips, visit www.cornwall.ca/water-conservation.

Treated Summary

The **average daily demand** from our *Water Purification Plant* in 2023 averaged **30.4% of our rated capacity** of 100,000m³ of water per day.

AVERAGE DAILY WATER DEMAND & CAPACITY USE SINCE 2002



TREATED WATER

	MIN.	AVG.	MAX
Turbidity	0.04	0.04	2.00
pH	7.56	7.67	8.09
colour	<2	<2	2

	TOTAL VOLUME	MAXIMUM FLOW	MINIMUM FLOW	AVERAGE FLOW	PRODUCTION CAPACITY
JANUARY	912,548 m ³	20,934 L/min	19,903 L/min	20,442 L/min	29.2 %
FEBRUARY	839,711 m ³	22,341 L/min	19,948 L/min	20,826 L/min	29.8 %
MARCH	924,612 m ³	24,556 L/min	18,895 L/min	20,713 L/min	29.6 %
APRIL	844,134 m ³	21,342 L/min	10,868 L/min	19,540 L/min	27.9 %
MAY	986,654 m ³	28,993 L/min	19,755 L/min	22,102 L/min	31.6 %
JUNE	1,037,754 m ³	31,960 L/min	20,459 L/min	24,022 L/min	34.3 %
JULY	1,005,770 m ³	26,733 L/min	20,251 L/min	22,530 L/min	32.2 %
AUGUST	961,858 m ³	23,523 L/min	19,516 L/min	21,547 L/min	30.8 %
SEPTEMBER	973,128 m ³	28,845 L/min	14,096 L/min	22,526 L/min	32.1 %
OCTOBER	933,108 m ³	25,137 L/min	19,504 L/min	20,902 L/min	29.9 %
NOVEMBER	880,805 m ³	21,642 L/min	18,843 L/min	20,389 L/min	29.1 %
DECEMBER	882,225 m ³	20,615 L/min	18,270 L/min	19,763 L/min	28.2 %

TOTAL: 11,182,307 m³ **AVERAGE:** 21,268 l/m or 30.4%

Our *Water Purification Plant* has the capacity to produce and distribute a maximum volume of **100,000 cubic meters per day (m³)** at a maximum flow rate of **70,000 litres per minute (l/m)**.

Our People

GENERAL MANAGER of INFRASTRUCTURE and MUNICIPAL WORKS: *Michael FAWTHROP*

DIVISION MANAGER of ENVIRONMENTAL SERVICES: *Stephen ROMANO*
Hafiz REHMAN

DWQMS REPRESENTATIVE & ASSET MANAGEMENT COORDINATOR:

SUPERVISOR of WATER PURIFICATION PLANT:

Owen O'KEEFE

SUPERVISORY CONTROL, DATA ACQUISITION & INSTRUMENTATION TECHNOLOGIST:

Beau CHEESEMAN

WATER PURIFICATION PLANT OPERATORS:

Julien CHARTRAND

Steve GIRARD

Jason ST. PIERRE

Jason FRASER

Jean MAINVILLE

Jason GADBOIS

Natasha POZEGA

WATER PURIFICATION PLANT MAINTENANCE TECHNICIANS:

WATER CONSERVATION COORDINATOR:

MANAGER of INFRASTRUCTURE:

Emma VANIER

MUNICIPAL ENGINEER:

Alex BOILEAU

INFRASTRUCTURE TECHNOLOGIST:

Robert RATHBUN

GEOGRAPHIC INFORMATION SYSTEM TECHNOLOGIST:

Denis LALONDE

INFRASTRUCTURE COORDINATOR:

Kevin PILON

ENGINEERING TECHNOLOGISTS:

Shafic HAMMOUD

Cameron GRAVELLE

MANAGER of MUNICIPAL WORKS:

Shawn O'BRIEN

PUBLIC WORKS DISPATCHER:

Joanne BEAULIEU

MUNICIPAL WORKS TECHNOLOGIST:

Jesse COLEMAN

MUNICIPAL WORKS ANALYST:

Janeise CARIS

SUPERVISOR of WATER DISTRIBUTION and WASTEWATER COLLECTION:

Daniel DROUIN

WATER DISTRIBUTION SUB-FOREMAN:

Scott CAIN

WATER DISTRIBUTION OPERATORS:

Denis BELANGER

Justin COLEMAN

Jason CROWE

Bryan DELAGE

Pat DECOSTE

Kevin DREW

Shawn HAMEL

Robert LAUZON

Jason LIDDLE

Gary LEDUC

Duncan MCDONALD

Tony PICOTTE

WATER DISTRIBUTION OPERATOR IN TRAINING:

Matthew LOCKER

WATER DISTRIBUTION SKILLED LABOURERS:

Cameron LECOMPTE

Matthew LEROUX

Larson PAYETTE

Mark STEELE

"The municipal water staff work **effectively** and **efficiently** to provide clean and safe drinking water to the community. The **proactive approach** the team takes ensures that the **highest quality drinking water** is delivered, and that **public safety** remains paramount. The continuous drinking water service is proudly provided year-round and in all seasons."

- Stephen ROMANO, M.Eng, P.Eng
Division Manager, Environment
City of Cornwall

www.cornwall.ca

Corporation of the City of Cornwall

Department of Infrastructure & Municipal Works
Environmental Services Division
861 Second Street West
Cornwall, Ontario, Canada
Phone: 613-932-2235
Fax: 613-932-4506

Unless otherwise specifically stated, the information contained herein is made available to the public by the *Environmental Services Department of the City of Cornwall* for use as general information only. The intent of this annual report is to inform the public of the performance of the **City of Cornwall's Drinking Water System** for the year **2023**.

Reference herein to any specific commercial product, process, service by trade name, trademark, manufacturer, or otherwise, does not constitute or imply its endorsement, recommendation, or favoring by the *Corporation of the City of Cornwall* or any entities thereof.

The views and opinions of the originators expressed therein do not necessarily state or reflect those of the *Corporation of the City of Cornwall* or any agency or entities thereof.

2023 DRINKING WATER QUALITY REPORT

Inquiries

SUPERVISOR of the WATER PURIFICATION PLANT

Owen O'KEEFE, C.Tech
613-930-2787 ext. 2573
ookeefe@cornwall.ca

SUPERVISOR of WATER DISTRIBUTION and WASTEWATER COLLECTION
and REPORT AUTHOR

Daniel DROUIN, A.Sc.T.
613-930-2787 ext. 2264
ddrouin@cornwall.ca

SOURCE WATER PROTECTION RISK ASSESSMENT OFFICIAL

Robert RATHBUN, C.E.T.
613-930-2787 ext. 2271
rrathbun@cornwall.ca

WATER CONSERVATION COORDINATOR

Natasha POZEGA
613-930-2787 ext. 2227
npozega@cornwall.ca

SCADA & INSTRUMENTATION TECHNOLOGIST and REPORT EDITOR

Beau CHEESEMAN
613-930-2787 ext. 2518
bcheeseman@cornwall.ca

Cornwall
ONTARIO CANADA

Preserve
Reduce
Conserve
Reuse
Save

WATER



Corporation of the City of Cornwall

360 Pitt Street
Cornwall, Ontario, Canada
K6J 3P9

Phone: 613-930-2787
www.cornwall.ca

© Corporation of the City of Cornwall, 2023

REUSE

USE THINGS MORE THAN ONCE
REPAIR
REGIFT!

AVOID WASTE!
BUY LESS
CONSERVE WATER

REDUCE



RECYCLE

SEPARATE WASTE MATERIALS
COMPOST
CHOOSE RECYCLABLE!

THINK
BEFORE YOU
PRINT



A scenic sunset over a body of water, likely a lake or bay. The sky is filled with dramatic, colorful clouds in shades of orange, yellow, and blue. The sun is low on the horizon, creating a bright reflection on the water's surface. In the foreground, there are reeds and a rocky shoreline. The overall mood is peaceful and natural.

TWENTY TWENTY-THREE

DRINKING WATER QUALITY SUMMARY REPORT

Corporation of the City of Cornwall
Department of Infrastructure & Municipal Works
Environmental Services Division



Ontario Drinking-Water Systems Regulation O. Reg. 170/03

Drinking-Water System Number:	22001049
Drinking-Water System Name:	Cornwall Drinking Water System
Drinking-Water System Owner:	Corporation Of The City Of Cornwall
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2023 – December 31, 2023

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>City Of Cornwall Water Purification Plant</p> <p>861 Second Street West</p> <p>Cornwall, Ontario</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [<input type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [<input type="checkbox"/>] No [<input type="checkbox"/>]</p>
--	---

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
St. Andrews West/Rosedale Distribution System	260001250

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____



Describe your Drinking-Water System

Source water is Lake St. Lawrence with pre-chlorination for zebra mussel control. Water Purification Plant is a conventional water treatment plant with chemically assisted filtration, Ultra-Violet disinfection, sodium hypochlorite disinfection, and advanced oxidation with hydrogen peroxide. The Water Purification Plant has a capacity of 100, 000 cubic metres per day, treats and distributes approximately 11 million cubic metres annually of potable water through 273 kilometres of distribution pipes.

List all water treatment chemicals used over this reporting period

Chlorine Liquefied Gas,
Polyaluminum Chloride Coagulant,
Sodium Hypochlorite.

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

: Water Main Replacement (\$1,877,000)
: Water Main Relining (\$975,000)
: Water Purification Plant PLC and Control Room Upgrades (\$950,000)
: Secondary Raw Water Intake Technical Studies (\$25,000)

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0 - 50	0 - 97	N/A	N/A
Treated	52	0 - 0	0 - 0	52	0 - 3
Distribution	773	0 - 0	0 - 0	260	0-11



Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	0.04 - 0.44 NTU
Chlorine	8760	0.42– 2.99 mg/L
Fluoride (If the DWS provides fluoridation)	N/A	N/A

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
None				

Summary of parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	16/01/23	0.0012	mg/L	no
Arsenic	16/01/23	<0.001	mg/L	no
Barium	16/01/23	0.02	mg/L	no
Boron	16/01/23	0.02	mg/L	no
Cadmium	16/01/23	<0.0001	mg/L	no
Chromium	16/01/23	<0.001	mg/L	no
Mercury	16/01/23	<0.0001	mg/L	no
Selenium	16/01/23	<0.001	mg/L	no
Sodium	16/01/23	14	mg/L	no
Uranium	16/01/23	<0.001	mg/L	no
Fluoride	16/01/23	0.12	mg/L	no
Nitrite	16/01/23	<0.10	mg/L	no
	11/04/23	<0.10	mg/L	no
	10/07/23	<0.10	mg/L	no
	10/10/23	<0.10	mg/L	no
Nitrate	16/01/23	0.32	mg/L	no
	11/04/23	0.31	mg/L	no
	10/07/23	0.21	mg/L	no
	10/10/23	0.23	mg/L	no



Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	N/A	N/A	0
Distribution	N/A	N/A	0

* On reduced monitoring schedule as per Schedule 15.1 distribution samples collected for pH and alkalinity only in 2023.

Summary of parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	16/01/23	<0.5	µg/L	no
Atrazine + N-dealkylated Metabolites	16/01/23	<1.0	µg/L	no
Azinphos-methyl	16/01/23	<2.0	µg/L	no
Benzene	23/01/23	<0.5	µg/L	no
Benzo(a)pyrene	16/01/23	<0.01	µg/L	no
Bromoxynil	16/01/23	<0.5	µg/L	no
Carbaryl	16/01/23	<5.0	µg/L	no
Carbofuran	16/01/23	<5.0	µg/L	no
Carbon Tetrachloride	23/01/23	<0.2	µg/L	no
Chlorpyrifos	16/01/23	<1.0	µg/L	no
Diazinon	16/01/23	<1.0	µg/L	no
Dicamba	16/01/23	<1.0	µg/L	no
1,2-Dichlorobenzene	23/01/23	<0.4	µg/L	no
1,4-Dichlorobenzene	23/01/23	<0.4	µg/L	no
1,2-Dichloroethane	23/01/23	<0.5	µg/L	no
1,1-Dichloroethylene (vinylidene chloride)	23/01/23	<0.5	µg/L	no
Dichloromethane	23/01/23	<4.0	µg/L	no
2-4 Dichlorophenol	16/01/23	<1.0	µg/L	no
2,4-Dichlorophenoxy acetic acid (2,4-D)	16/01/23	<1.0	µg/L	no
Diclofop-methyl	16/01/23	<0.9	µg/L	no
Dimethoate	16/01/23	<2.5	µg/L	no
Diquat	16/01/23	<5	µg/L	no
Diuron	16/01/23	<10	µg/L	no
Glyphosate	16/01/23	<10	µg/L	no
Malathion	16/01/23	<0.5	µg/L	no
2 methyl-4-chlorophenoxyacetic acid (MCPA)	16/01/23	<10	µg/L	no
Metolachlor	16/01/23	<1.0	µg/L	no
Metribuzin	16/01/23	<5.0	µg/L	no



Monochlorobenzene	23/01/23	<0.5	µg/L	no
Paraquat	16/01/23	<1	µg/L	no
Pentachlorophenol	16/01/23	<1.0	µg/L	no
Phorate	16/01/23	<0.5	µg/L	no
Picloram	16/01/23	<5.0	µg/L	no
Polychlorinated Biphenyls(PCB)	16/01/23	<0.1	µg/L	no
Prometryne	16/01/23	<0.25	µg/L	no
Simazine	16/01/23	<1.0	µg/L	no
THM	16/01/23	23.5	µg/L	no
	11/04/23	17.5	µg/L	no
	10/07/23	53.9	µg/L	no
	10/10/23	46.8	µg/L	no
(NOTE: show latest annual average)	2023 Avg	35.4	µg/L	no
Terbufos	16/01/23	<0.4	µg/L	no
Tetrachloroethylene	23/01/23	<0.3	µg/L	no
2,3,4,6-Tetrachlorophenol	16/01/23	<1.0	µg/L	no
Triallate	16/01/23	<1.0	µg/L	no
Trichloroethylene	23/01/23	<0.3	µg/L	no
2,4,6-Trichlorophenol	16/01/23	<0.7	µg/L	no
Trifluralin	16/01/23	<1.0	µg/L	no
Vinyl Chloride	23/01/23	<0.2	µg/L	no
Chloroform (Distribution)	16/01/23	13.8	µg/L	no
	11/04/23	10.2	µg/L	no
	10/07/23	33.8	µg/L	no
	10/10/23	29.0	µg/L	no
Bromoform (Distribution)	16/01/23	<0.4	µg/L	no
	11/04/23	<0.4	µg/L	no
	10/07/23	<0.4	µg/L	no
	10/10/23	<0.4	µg/L	no
Dibromochloromethane (Distribution)	16/01/23	2.6	µg/L	no
	11/04/23	2.4	µg/L	no
	10/07/23	5.3	µg/L	no
	10/10/23	4.8	µg/L	no
Bromodichloromethane (Distribution)	16/01/23	7.1	µg/L	no
	11/04/23	4.9	µg/L	no
	10/07/23	14.8	µg/L	no
	10/10/23	13.0	µg/L	no
Total Haloacetic Acids (Distribution)	16/01/23	16.0	µg/L	no
	11/04/23	10.1	µg/L	no
	10/07/23	30.8	µg/L	no
	10/10/23	20.8	µg/L	no
(NOTE: show latest annual average)	2023 Avg	19.4	µg/L	no



Chloroacetic Acids (Distribution)	16/01/23	<2.0	µg/L	no
	11/04/23	<2.0	µg/L	no
	10/07/23	<2.0	µg/L	no
	10/10/23	<2.0	µg/L	no
Bromoacetic Acid (Distribution)	16/01/23	<2.0	µg/L	no
	11/04/23	<2.0	µg/L	no
	10/07/23	3.1	µg/L	no
	10/10/23	<2.0	µg/L	no
Dichloroacetic Acid (Distribution)	16/01/23	8.0	µg/L	no
	11/04/23	5.0	µg/L	no
	10/07/23	17.8	µg/L	no
	10/10/23	10.6	µg/L	no
Dibromoacetic Acid (Distribution)	16/01/23	<2.0	µg/L	no
	11/04/23	<2.0	µg/L	no
	10/07/23	<2.0	µg/L	no
	10/10/23	<2.0	µg/L	no
Trichloroacetic Acid (Distribution)	16/01/23	8.0	µg/L	no
	11/04/23	5.1	µg/L	no
	10/07/23	9.9	µg/L	no
	10/10/23	10.2	µg/L	no

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
None			